



**KRISHI VIGYAN KENDRA-KOTPUTLI, JAIPUR
DIRECTORATE OF EXTENSION EDUCATION
SRI KARAN NARENDRA AGRICULTURE UNIVERSITY
JOBNER, JAIPUR (RAJASTHAN)**



**Lt. Col (Dr.) S.S. Shekhawat
Senior Scientist & Head**

**Email: pc.kvk.gonera@sknau.ac.in
Mobile No. 9408660365**

No. KVK/KTP/2026/ 414

Dated: 16.2.2026

CORRIGENDUM

With reference to the E-Tender Notice No. KVK/KTP/2026/407 dated 09.02.2026 for "Supply & Installation of Solar-System 40 KW". It is hereby informed to all prospective bidders that the correction shall be treated as under.

S.No.	Existing Entry	To be Read as
1.	INS Solar	INA Solar
2.	REZON SOLAR	RAYZON SOLAR
3.	Galvanized Iron suitable angle/pipe	Galvanized Iron Structure pipe size- 2mm thick pipe (Leg-75mmx75mm, RAFTER-80mmx40mm, PARLINS-40mmx40mm)
4.	LA	ESE LIGHTNING ARRASTOR (100 meter range)
5.	Copper bounded earthing rod	pure copper strip road (3 meter earthing rod with chemical bag)
6.	HARDWARE	STEELNESS STEEL NUT BOLT FOR MOUNTING STRUCTURE
7.	Equipment & System Warranty Invertor 08 Year	Invertor- 10 Year against manufacturer defects only.

Further the solar system includes ACDB and DCDB with surge protection device.

All the other Terms and Conditions, specifications and clauses of the tender document shall remain unchanged. This corrigendum shall form an integral part of the bidding document and must be signed and submitted/uploaded by all bidders along with their bid.

Supern Singh
Senior Scientist & Head

Copy to the following for information &n/a.

1. The comptroller, SKNAU, Jobner.
2. The Treasure Officer, SKNAU, Jobner.
3. In-charge CIMCA, SKNAU, Jobner to upload tender on <http://eproc.rajasthan.gov.in>
4. Convenor & all members of Tender committee, KVK, Kotputli
5. Account Section, KVK, Kotputli
6. All notice board/KVK, Kotputli/Tahsil office/Panchayat office, KVK, Kotputli.

Supern Singh
Senior Scientist & Head